Interlake-Eastern
Regional Health Authority

Pressure Differential Log

To be completed at the beginning and end of each work day AND every time the alarm goes off.

Note: *The manometer reading must be* ***-7.5 Pa or greater (-0.03 in wc)***

Date	Time	Manometer Reading	Corrective Action (if applicable)	Initials

Table 1. Pascals to Inches Water Column

-20 Pa	-0.08 in wc
-17.5 Pa	-0.07 in wc
-15 Pa	-0.06 in wc
-12.5 Pa	-0.05 in wc
-10 Pa	-0.04 in wc
-7.5 Pa	-0.03 in wc
-5 Pa	-0.02 in wc
-2.5 Pa	-0.01 in wc
0 Pa	0 in wc
2.5 Pa	0.01 in wc

Table1, adapted from Shared Health IPC Provincial Working Group for Construction (2024).